



**BUREAU
VERITAS**

Certificate of compliance

Applicant: NingBo Deye Inverter Technology Co., Ltd.
No. 26 South YongJiang Road, Daqi, Beilun, NingBo
China

Product: Photovoltaic (PV) inverter

Model: SUN-M130G4-EU-Q0, SUN-M160G4-EU-Q0,
SUN-M180G4-EU-Q0, SUN-M180G4-EU-Q0-P,
SUN-M200G4-EU-Q0, SUN-M200G4-EU-Q0-P,
SUN-M220G4-EU-Q0

The device is designed to work as a generation unit of the type: A

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

EN 50549-10:2022

Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: ASUE-ESH-P24010377

Certification Program: NSOP-0032-DEU-ZE-V01

Certificate number: U24-0360

Date of issue: 2024-05-13

Certification body



Domenik Koll
Head of Energy Systems



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



**BUREAU
VERITAS**

Annex to the EN 50549-1 certificate of compliance No. U24-0360

Appendix

Extract from test report according to EN 50549-1

No. ASUE-ESH-P24010377

Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016

Manufacturer / applicant	NingBo Deye Inverter Technology Co., Ltd. No. 26 South YongJiang Road, Daqi, Beilun, NingBo China
---------------------------------	---

Micro-generator Type	Photovoltaic inverter
-----------------------------	-----------------------

	SUN-M130G4-EU-Q0	SUN-M160G4-EU-Q0	SUN-M180G4-EU-Q0	SUN-M180G4-EU-Q0-P
Photovoltaic (DC)				
MPP DC voltage range [V]	25-55	25-55	25-55	25-55
Max DC voltage [V]	60	60	60	60
Input DC current [A]	15*4	15*4	15*4	18*4
Connection (AC)				
Output AC voltage [V]	230, L/N/PE, 50/60Hz	230, L/N/PE, 50/60Hz	230, L/N/PE, 50/60Hz	230, L/N/PE, 50/60Hz
Max AC current [A]	5,7	7,0	7,9	7,9
Active Power [W]	1300	1600	1800	1800
Apparent power [VA]	1300	1600	1800	1800

	SUN-M200G4-EU-Q0	SUN-M200G4-EU-Q0-P	SUN-M220G4-EU-Q0	--
Photovoltaic (DC)				
MPP DC voltage range [V]	25-55	25-55	25-55	--
Max DC voltage [V]	60	60	60	--
Input DC current [A]	15*4	18*4	18*4	--
Connection (AC)				
Output AC voltage [V]	230, L/N/PE, 50/60Hz	230, L/N/PE, 50/60Hz	230, L/N/PE, 50/60Hz	--
Max AC current [A]	8,7	8,7	9,6	--
Active Power [W]	2000	2000	2200	--
Apparent power [VA]	2000	2000	2200	--

Firmware version	0308-1426
-------------------------	-----------

Description of the structure of the power generation unit:

The power generation unit is equipped with a DC and line-side EMC filter. The power generation unit has galvanic isolation between DC input and AC output (HF transformer). Output switch-off is performed with single-fault tolerance based on the inverter bridge and one series-connected relay in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.



BUREAU
VERITAS

Annex to the EN 50549-1 certificate of compliance No. U24-0360

Appendix

Extract from test report according to EN 50549-1

No. ASUE-ESH-P24010377

Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.